




Republic of the Philippines
Department of Agriculture

SUGAR REGULATORY ADMINISTRATION

Sugar Center Bldg., North Avenue, Diliman, Quezon City, Philippines 1101
TIN 000-784-336
Website: <http://www.sra.gov.ph>
Email Address: srahead@sra.gov.ph
Tel No. (632) 8929-3633, (632) 3455-2135, (632) 3455-3376



SUPPLEMENTAL/BID BULLETIN NO. 1
Supply and Delivery of Generating Set
Bid Reference No. 2023-COB-04

With reference to the Bidding Documents for the Supply and Delivery of Generating Set, posted at the PhilGEPS and SRA websites, this Supplemental/Bid Bulletin is being issued to clarify, amend, modify some items in the provisions of the Bidding Documents in response to the recommendations raised by prospective bidders, as follows:

Section III. Bid Data Sheet			
From		To	
ITB Clause 5.3	For this purpose, contracts similar to the Project shall be:	ITB Clause 5.3	For this purpose, contracts similar to the Project shall be:
	a. Generating Set		a. Generating Set, 250kva/200kw
	b. completed within five (5) years prior to the deadline for the submission and receipt of bids.		b. completed within five (5) years prior to the deadline for the submission and receipt of bids.

Section VII. Technical Specifications			
From		To	
A.1	250kva/200kw	A.1	250kva/200kw; 230 volts
A.12	Automatic Transfer Switch <i>(Should be compatible with the above-specified engine)</i>	A.12	Automatic Transfer Switch <i>(Should be compatible with the above-specified engine)</i> ATS Circuit Breaker – 800 Amps/3-phase
A.14	Removal of the old unit	A.14	Removal of the old unit to include pull-out of existing 3 sets manual transfer switch (400 amps) and set-up 3 sets main distribution panel (MDP) with 400 Amp 3-Phase (existing)
A.15	Installation of the new unit <i>(Includes carpentry works, rectification works and proper positioning)</i>	A.15	Installation of the new unit (includes carpentry works, rectification works and proper positioning) to include: <ul style="list-style-type: none"> - Busbar with enclosure in between ATS to 3 main distribution panel (MDP) - Installation of main disconnect circuit breaker for normal/CENECO. <p>Note: Existing circuit breaker of generator to be used</p>



Management System
ISO 9001:2015
www.tuv.com
ID 310508567



The Supplemental/Bid Bulletin No. 1 shall form part of the Bidding Documents. Any provisions in the Bidding Documents inconsistent herewith is hereby amended, modified and superseded accordingly.

For the guidance and information of all concerned.

Issued this 7th day of June 2023.



ATTY. IGNACIO S. SANTILLANA
Chairperson, Regional Bids and Awards Committee